

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for Sayreville Water Department

On February 21, 2020, we became aware that our system failed to collect the correct number of drinking water samples. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did to correct this situation.

** We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the 8/26/19 - 9/8/19 and 12/30/19 – 01/12/20 compliance periods, we did not monitor for pH, orthophosphate and temperature as required in our Water Quality Parameters sampling plan and therefore cannot be sure of the quality of your drinking water during that time.**

We were required to sample bi-weekly and sampled on a bi-monthly basis during these periods.

What should I do?

There is nothing you need to do at this time. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

What is being done?

We adjusted our monitoring schedule on February 21, 2020 and will continue sampling on a bi-weekly basis to remain in compliance.

For more information, please contact David Leitner at 732-390-7067 or water@sayreville.com.

** Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.**

This notice published by the Sayreville Water Department.
State Water System ID#: 1219001.